



## USE OF SOLAR AND WIND ENERGY SOURCES IN AUTONOMOUS NETWORKS

Suyarov A. O.

Assistant Teacher, Jizzakh Polytechnic Institute, Department of "Energy"

Sorimsokov U. S.

Assistant Teacher, Jizzakh Polytechnic Institute, Department of "Energy"

Narimanov B. A.

Assistant Teacher, Jizzakh Polytechnic Institute, Department of "Energy"

Nasullayev M. O.

Student, Jizzakh Polytechnic Institute, Department of "Energy"

### Annotation

The article discusses issues related to the use of solar and wind installations as primary sources of energy, which make it possible to create completely autonomous power plants that provide guaranteed year-round coverage of electrical loads in various climatic conditions.

**Keywords:** renewable energy sources, autonomous networks, solar installations, wind installations, energy characteristics.

### Introduction

In many countries of the world, powerful renewable energy systems are based, as is known, on the use of mono-wind, mono-solar photovoltaic or mono-solar heat generating complexes. At the same time, there are numerous examples of the simultaneous use of two or more types of RES. In Canada, to provide power to remote villages, hybrid schemes are used - wind-diesel and wind - driven. Hydrogen is used to generate electricity in internal combustion engines. The wind-generating scheme is being applied at the Prince Edward Island Wind-Hydrogen Village and in the city of Ramea. The power of the hydrogen generator is 250 kW. It saves 120 thousand liters of fuel annually, thereby preventing emissions into the atmosphere:

$$CO_2 - 320 \text{ t}, NO_x - 6,8 \text{ t}, SO_2 - 0,6 \text{ t} [1].$$





## Experience in operating complex renewable energy systems abroad

The TAFE Tasmania Institute (Australia) has a complex consisting of two wind turbines, an electrolyzer and a diesel plant, which is adapted to work with hydrogen. An example of the effective use of a wind-diesel energy complex: on Fair Island (Scotland) for a village with a population of 70 people, a power plant with two diesel power plants was built, the first (power - 20 kW) was sufficient for electricity supply in summer, and the other (50 kW) - for electricity supply in winter (see Table 1)[2]. Wind conditions on the island are very favorable. The average wind speed is 9.6 m / s. In June 1982, a 50 kW wind farm was installed there. Since then, energy production has increased 3.7 times. The operation of the VDU on Fair Island showed that the cost of electricity received from the diesel power plant was 8 cents / kWh, and from the wind farm 3.5 cents / kWh. A special device was developed for this station, which showed when the energy meter switched to a higher tariff[3].

Table 1 Energy production at an integrated wind-diesel plant (WDP) (Fair Island) for a year of operation

| Energy production on Fair Island in one year | Power generation  |                      |
|--|-------------------|----------------------|
| Power plant                                  | abs. number, kW h | Relative quantity, % |
| Integrated VDU                               | 185 024           | 100,00               |
| Wind farm                                    | 168 895           | 91,28                |
| DES  | 16 147            | 8,72                 |

The study found that the most likely hours of sunshine are distributed symmetrically around noon [4].

## Analysis of Complex Renewable Energy Systems

In the course of the study, scientists established the averaged values of the intensity of solar radiation  $h_s$  with the distribution of the duration of sunshine ( $S$ ) symmetrically relative to noon. It is proposed to determine the intensity of solar radiation as

$$h_s = h_0 \cdot b_s \cdot \exp\left(-0,25 \frac{S}{S_0}\right),$$

Where,  $h_0 = 1360 \text{ Bt/m}^2$  – solar constant;  $b_s$  – coefficient depending on the season is given in table. 2;  $S_0$  – possible duration of sunshine (day length), [h].

Coefficient  $b_s$  shows the fraction of the solar constant arriving on a horizontal surface at noon. The product of the coefficient  $b_s$  by the solar constant allows you to





determine the intensity of solar radiation at noon. Coefficient  $b_s$  has a pronounced annual course and is of greatest importance in the summer [5].

Table 2 Parameter of the equation of the intensity of solar radiation "within the day" in the southern Urals

| Parameters | Monthly |     |      |     |      |     |      |     |      |     |     |     |
|------------|---------|-----|------|-----|------|-----|------|-----|------|-----|-----|-----|
|            | 1       | 2   | 3    | 4   | 5    | 6   | 7    | 8   | 9    | 10  | 11  | 12  |
| $b_s$      | 0,3     | 0,4 | 0,45 | 0,5 | 0,55 | 0,6 | 0,55 | 0,5 | 0,45 | 0,4 | 0,3 | 0,2 |

From the average intensity of solar radiation, given for the corresponding duration of sunshine, it is easy to determine the solar radiation for a given time  $S$ :  $H_s = h_s S$ . For an objective assessment of the incoming solar energy, it is necessary to know the probability of the appearance of the sunshine duration, which characterizes its supply  $p(S)$ . The probabilistic characteristic of the daytime sunshine duration is determined for each month according to the observations of the meteorological service [6].




Figure 1. Dependence of total solar radiation on the duration of sunshine within the day

It is known that the specific power of the wind flow is represented as an average value for the calculation period and it is necessary to know the average value  $v^3$ . This requires knowing the distribution of the frequency of the wind speed, which can be determined for each month from the observation data [7].

It is known that the specific power of the wind flow is represented as an average value for the calculation period and it is necessary to know the average value  $v^3$ . This requires knowing the distribution of the frequency of the wind speed, which can be determined for each month from the observation data.





Then, by empirical repeatability ( $t_{*(v)}$ ) or the differential function  $f(v)$  of the wind speed distribution, you can determine the expected average power of the wind flow for the design period,  $\text{W/m}^2$  [8],

$$\bar{N}_0 = \frac{1}{2} \rho \int_0^{\infty} v^3 f(v) dv = \frac{1}{2} \rho (v^3)_{cp}$$

It is recommended to determine the average value of the wind flow power per day. Then the wind speed at which the average daily wind power is expected is presented as the energy characteristic of the wind. The dependence of the energy characteristic of the wind flow on the average wind speed (see Fig. 2) is well approximated by an equation of the form

$$v_{cp,M} = 1,4 + 1,1 v_{cp},$$

Where  $v_{cp,M}$  – average wind speed per month,  $\text{m/c}$




Figure 2. Dependence of the energy characteristics of the wind flow on the average wind speed

The lack of research was the lack of an implemented system for the integrated use of various types of RES for a full-scale approbation of theoretical calculations [9].

## Conclusions

In general, the complex use of renewable energy sources has been limited until recently due to objective circumstances and the uncompetitiveness (high cost) of equipment for large-scale use. However, the increase in tariffs for energy services and fossil fuels brings the issue of increasing the efficiency of using available renewable resources to a new level. In connection with the above examples, the





problem arises of continuing research and finding optimal solutions for the complex application of renewable energy sources proposed in this study.

Based on this, the following conclusions can be drawn:

- The use of solar and wind installations as primary energy sources makes it possible to create fully autonomous power plants that provide guaranteed year-round coverage of electrical loads, at least for small consumers, in various climatic conditions;
- The most effective are combined installations that optimally (depending on climatic conditions) combine solar and wind installations;
- Development of work is required on experimental development and further improvement of mathematical models of autonomous power plants on renewable energy sources, which are the necessary basis for substantiating their optimal configurations, taking into account significantly different real climatic operating conditions and consumer characteristics.

## References

1. Suyarov A. Power Loss Minimization in Distribution System with Integrating Renewable Energy Resources //International Journal of Engineering and Information Systems (IJE AIS). – 2021. – T. 5. – №. 2. – C. 37-40.
2. Hasanov M. et al. Optimal Integration of Photovoltaic Based DG Units in Distribution Network Considering Uncertainties //International Journal of Academic and Applied Research (IJAAR), ISSN. – 2021. – C. 2643-9603.
3. Boliev A. M. INCREASING THE ECONOMIC EFFICIENCY OF THE RENEWABLE ENERGY SYSTEM IN UZBEKISTAN //Journal of Academic Research and Trends in Educational Sciences. – 2022. – T. 1. – №. 4. – C. 130-135.
4. Джуманов А. Н. и др. ИЗМЕРИТЕЛЬНЫЕ ТРАНСФОРМАТОРЫ ТОКА //World science: problems and innovations. – 2021. – C. 76-78.
5. Mamasaliev O. Theoretical Foundations of Energy Saving //International Journal of Engineering and Information Systems (IJE AIS) ISSN. – 2021. – C. 293-296.
6. Tanirbergenov R., Suyarov A., Urinboy J. Application of Solar and Wind Units as Primary Energy Sources in Autonomous Networks //International Journal of Advanced Research in Science, Engineering and Technology. – 2020. – T. 7. – №. 9.
7. Hasanov M. et al. Optimal Integration of Wind Turbine Based Dg Units in Distribution System Considering Uncertainties //Khasanov, Mansur, et al."





Rider Optimization Algorithm for Optimal DG Allocation in Radial Distribution Network." 2020 2nd International Conference on Smart Power & Internet Energy Systems (SPIES). IEEE. – 2020. – C. 157-159.

8. Khonturaev I. et al. Atom Search Optimization Algorithm for Allocating Distributed Generators in Radial Distribution Systems //E3S Web of Conferences. – EDP Sciences, 2021. – T. 264. – C. 04084.
9. Kurbanov A. et al. An Appropriate Wind Model for The Reliability Assessment of Incorporated Wind Power in Power Generation System //E3S Web of Conferences. – EDP Sciences, 2021. – T. 264.
10. Absalamovich N. B. Research on the use of alternative energy sources in Uzbekistan: Problems and prospects //ACADEMICIA: An International Multidisciplinary Research Journal. – 2020. – T. 10. – №. 11. – С. 763-768.
11. Нариманов Б. А., Шодийева Н. Ш. К. ОБ ПОЯТИЕ ГИДРОАККУМУЛИРУЮЩЕЙ ЭЛЕКТРОСТАНЦИИ (ГАЭС) //Academic research in educational sciences. – 2021. – Т. 2. – №. 5. – С. 286-293.
12. Нариманов Б. А. ОПРЕДЕЛЕНИЕ ОРБИТАЛЬНОГО ДВИЖЕНИЯ СПУТНИКОВ //Современная наука: проблемы, идеи, инновации. – 2019. – С. 76-81.
13. Narimanov B. A. FORECASTING OF PROCESSES THE TURNOVER AND STRUCTURE OF THE FINANCIAL RESOURCES OF THE BANKING SECTOR //Academic research in educational sciences. – 2021. – Т. 2. – №. 4. – С. 1980-1991.
14. Olimov O. Basic Ways to Improve Efficiency Operations of Asynchronous Electric Drives //International Journal of Engineering and Information Systems (IJE AIS) ISSN. – 2020. – C. 107-108.
15. Olimov O., Khazratkulova X. USE WIND ENERGY IN THE CONDITIONS OF JIZZAKH REGION (UZBEKISTAN) //InterConf. – 2020.
16. Nosirovich O. O. Energy saving and application of frequency converters and soft start devices //ACADEMICIA: AN INTERNATIONAL MULTIDISCIPLINARY RESEARCH JOURNAL. – 2021. – Т. 11. – №. 2. – С. 1232-1235.
17. Fazliddin A., Tuymurod S., Nosirovich O. O. Use Of Recovery Boilers At Gas-Turbine Installations Of Compressor Stations And Thyristor Controls //The American Journal of Applied sciences. – 2021. – Т. 3. – №. 09. – С. 46-50.
18. Alisher B. Frequency-Controlled Electric Drive of Pumping Units (October 30, 2020) //International Journal of Engineering and Information Systems (IJE AIS) ISSN. – С. 109-111.





19. Болиев А. М. Влияние пандемии COVID-19 на энергетический сектор. Основные проблемы в секторах возобновляемых источников энергии //ИННОВАЦИОННОЕ РАЗВИТИЕ НАУКИ И ОБРАЗОВАНИЯ. – 2021. – С. 169-179.
20. Alisher B. Frequency-Controlled Electric Drive of Pumping Units //International Journal of Engineering and Information Systems (IJE AIS) ISSN. – 2020. – С. 109-111.
21. Alisher B., Mirzaev U. Technical and Economic Indicators of a Microhydroelectric Power Station in Agriculture //International Journal of Engineering and Information Systems (IJE AIS) ISSN. – 2020. – С. 51-56.